

**Karnataka Fire and Emergency Services Department**



Office of the Chief fire officer,  
Bangalore west zone, High-ground fire station premises,  
Sheshadri road, Bangalore – 560 009.  
080 – 22971523 / 500 / 600. Fax : 080 – 22971523.



No.510/CC/CFO/BWZ/2025.

28-07-2025.

**To.**

**The Authorized Signatory.**

**Shridevi Institute of Engineering & Technology College,  
NH-04, Sira road, Tumkur taluk,  
Tumkur District.**

Sir

**Sub:-** Issue of ‘Fire safety Compliance Certificate’ with respect to fire prevention, fighting and evacuation measures maintained/ required at **Shridevi Institute of Engineering & Technology College**, situated at NH-04, Sira road , Tumkur taluk, Tumkur.

**Ref :-** 1.Our department FSR.No.61/FSR/DFO/TMK/2024, Dated:-20-04-2024.  
2.Your letter dated:10-06-2025.

\* \* \* \* \*

With reference to subject cited (1) above a ‘Fire Safety Recommendation’ was issued to the premises of **Shridevi Institute of Engineering & Technology College**, situated at NH-04, Sira road , Tumkur taluk, Tumkur with a condition to fulfill the recommendations and compliance the same within 3 months to the above building.

With reference cited (2) above, the management of **Shridevi Institute of Engineering & Technology College** situated at NH-04, Sira road , Tumkur taluk, Tumkur had requested this office for issuing of fire safety compliance certificate from our department In this regard I have inspected the above premises on 12-07-2025 and it is confirmed that they have complied all recommendations communicated in our department Fire safety recommendation certificate.

....2

Under the above circumstances the Karnataka Fire & Emergency Services Department was issued the "**Fire Safety Compliance Certificate**" to **Shridevi Institute of Engineering & Technology College**, situated at NH-04, Sira road , Tumkur taluk, Tumkur had Subject to proper maintenance of fire fighting systems in good working condition and at least 40% of employees should be trained in basic fire fighting at our R.A.Mudkur fire and Emergency training academy, Bannerughatta road, Bangalore.

*This fire safety compliance certificate was issued for a period of only Two years from the date of issue and it is renewable.*

Yours faithfully.

